

 <p>State of Ohio Weatherization Program Standards</p>	Section	MECHANICAL SYSTEMS INSPECTION
	Subject	Electrical Safety

SERVICE ENTRY BOX 201-8.1

Note the location and condition of the main service entry box. Note if it is properly mounted in an appropriate location. **location of box**
201-8.1a

Determine if the main service entry box is properly grounded according to the NEC. **grounding**
201-8.1b

Determine the type and amp rating of the main service box. **type of box**
201-8.1c

Determine existing wire types and the location and condition of each type present. **type of wiring**
201-8.1d

Note the sizes of the existing fuses/breakers and determine if they are properly sized for their circuits. **fuse/circuit size**
201-8.1e

If the inspector determines that a hazardous situation exists, inform the customer of the problem. Have the problem corrected if it is possible within the scope of the HWAP. **hazards**
201-8.1f

