



State of Ohio  
Weatherization Program  
Standards

|         |  |
|---------|--|
| Section | <b>MECHANICAL SYSTEMS<br/>INSTALLATION</b> |
| Subject | <b>Electrical Safety</b>                   |

*SERVICE ENTRY BOX/CIRCUITS 301-8.1*

Have the electric utility company replace the main electrical supply if it is unsafe. **main power supply**  
301-8.1a

When needed, replace the main service panel according to the NEC considering amp size, number of circuits, and wire size of circuits. **main supply panel**  
301-8.1b

Circuit wiring must be installed in conformance to the NEC. **circuits**  
301-8.1c