



State of Ohio
Weatherization Program
Standards

Section **MOBILE HOME MECHANICAL
SYSTEMS FINAL INSPECTION**

Subject **Electrical Safety**

SERVICE ENTRY BOX 801-8.1

Ensure the main service entry box is properly mounted in an appropriate location (away from dampness and other hazards).

location of box
801-8.1a

Ensure the main service entry box is properly grounded according to the NEC.

grounding
801-8.1b

Ensure existing wire types, and that the location and condition of each type is hazard free.

type of wiring
801-8.1c

Ensure the existing fuses/breakers are properly sized for their circuits.

fuse/circuit size
801-8.1d

Ensure that a copy of the Certificate of Insulation is present at the service box if applicable.

**certificate of
insulation**
801-8.1e